



#### BILL OF MATERIALS:-

S.No.	SYMBOL	TYPE	DESCRIPTION	QNTY.
01	⊗	SW1	70W HPSV AC NORMAL WELL GLASS LUMINAIRE (CGL - SWV1207/EQUIVALENT)	02 Nos.
02	-	-	3Cx4 Sq.mm. Cu. ARMoured CABLE	45M
03	-	-	40NB 'B' CLASS PIPE	02 Nos.
04	-	-	150WX200HX6 THK. GALVANISED M.S.PLATE	02 Nos.
05	-	-	8MM DIA. 'U' BOLT	04 Nos.

#### NOTES:

- ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS ARE IN METRES.
- CABLE ROUTING SHOWN IS ONLY INDICATIVE. THE ACTUAL CABLE ROUTING SHALL BE DONE AS PER SITE CONDITION.
- LP AND FIXTURE CIRCUIT NUMBERING SHALL BE READ AS FOLLOWS

#### REFERENCE DRAWINGS:-

- PE-DG-319-100-M001 - PLOT PLAN

RO	27.12.13	FOR APPROVAL				KR			DJS		
REV.	DATE	DESCRIPTION				DRN.	STR.	MECH.	ELEC.	INST.	
						APPROVED BY				B	
FICHTNER Consulting Engineers (India) Private Limited Chennai		ONGC TRIPURA POWER COMPANY PRIVATE LIMITED. 726.6 MW COMBINED CYCLE POWER PROJECT PALLATANA, TRIPURA									
		SIGNATURE	DATE	TITLE  STORM WATER PIT -2  LIGHTING LAYOUT						A	
DRAWN	KR	27.12.13									
DESIGNED	RSV	27.12.13									
CHECKED	RSV	27.12.13									
DEPT.HEAD	DJS	27.12.13									
PROJ.MGR.	DKS/RUV	27.12.13									
RELEASED FOR	PRELIMINARY		DEPT. ELECT.		JOB NO.		1113112		SCALE: 1:125		REV.
	TENDER		DWG.NO.		30-1113112-E-002						R0
	ENGINEERING										
4		3		2		SHEET : 02 OF 04		1		SIZE-A3	